

School Name: Honeoye Elementary School

Lab EPA id#: NY 10478

Method of Analysis: EPA Method 200.8

LabID#	School Sample ID#	Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result mcg/L (ppb)	Lab Report Receipt Date	Action Taken for Outlets Greater than 15 mcg/L
NY #10478	70174133001	5/20/2021	Rm 10	Drinking fountain	Initial	<1.0	6/9/2021	n/a
NY #10478	70174133002	5/20/2021	Rm 10	Classroom sink	Initial	4.8	6/9/2021	n/a
NY #10478	70174133005	5/20/2021	Rm 10	Bathroom sink	Initial	11	6/9/2021	n/a
NY #10478	70174133006	5/20/2021	Rm 12	Drinking fountain	Initial	1.8	6/9/2021	n/a
NY #10478	70174133007	5/20/2021	Rm 12	Classroom sink	Initial	8.1	6/9/2021	n/a
NY #10478	70174133008	5/20/2021	Rm 12	Bathroom sink	Initial	15	6/9/2021	n/a
NY #10478	70174133009	5/20/2021	Rm 14	Brinking fountain	Initial	1.1	6/9/2021	n/a
NY #10478	70174133010	5/20/2021	Rm 14	Classroom sink	Initial	5	6/9/2021	n/a
NY #10478	70174133011	5/20/2021	Rm 14	Bathroom sink	Initial	8.5	6/9/2021	n/a
NY #10478	70174133012	5/20/2021	Rm 16	Classroom sink	Initial	<1.0	6/9/2021	n/a
NY #10478	70174133013	5/20/2021	Rm 16	Drinking fountain	Initial	3.6	6/9/2021	n/a
NY #10478	70174133014	5/20/2021	Rm 16	Bathroom sink	Initial	2.7	6/9/2021	n/a
NY #10478	70174133015	5/20/2021	Rm 18	Bathroom sink	Initial	3.6	6/9/2021	n/a
NY #10478	70174133016	5/20/2021	Rm 18	Classroom sink	Initial	1	6/9/2021	n/a
NY #10478	70174133017	5/20/2021	Rm 18	Drinking fountain	Initial	12.3	6/9/2021	n/a
NY #10478	70174133018	5/20/2021	Rm 20	Classroom sink	Initial	<1.0	6/9/2021	n/a
NY #10478	70174133019	5/20/2021	Rm 20	Drinking fountain	Initial	4.1	6/9/2021	n/a
NY #10478	70174133020	5/20/2021	Rm 20	Bathroom sink	Initial	8.4	6/9/2021	n/a
NY #10478	70174133021	5/20/2021	Rm 22	Classroom sink	Initial	4.8	6/9/2021	n/a
NY #10478	70174133022	5/20/2021	Rm 22	Drinking fountain	Initial	<1	6/9/2021	n/a
NY #10478	70174133023	5/20/2021	Rm 22	Bathroom sink	Initial	4.7	6/9/2021	n/a
NY #10478	70174133024	5/20/2021	Rm 24	Classroom sink	Initial	4.3	6/9/2021	n/a
NY #10478	70174130001	5/20/2021	Rm 24	Drinking fountain	Initial	1.1	6/9/2021	n/a
NY #10478	70174130002	5/20/2021	Rm 24	Bathroom sink	Initial	7.2	6/9/2021	n/a
NY #10478	70174130003	5/20/2021	Rm 26	Classroom sink	Initial	3.5	6/9/2021	n/a
NY #10478	70174130004	5/20/2021	Rm 26	Drinking fountain	Initial	<1	6/9/2021	n/a
NY #10478	70174130005	5/20/2021	Rm 26	Bathroom sink	Initial	6.3	6/9/2021	n/a
NY #10478	70174130006	5/20/2021	Rm 28	Classroom sink	Initial	3.5	6/9/2021	n/a
NY #10478	70174130007	5/20/2021	Rm 28	Drinking fountain	Initial	<1	6/9/2021	n/a
NY #10478	70174130008	5/20/2021	Rm 28	Bathroom sink	Initial	1.2	6/9/2021	n/a
NY #10478	70174130009	5/20/2021	Rm 29	Classroom sink	Initial	1.3	6/9/2021	n/a
NY #10478	70174130010	5/20/2021	Rm 30	Classroom sink	Initial	2.4	6/9/2021	n/a
NY #10478	70174130011	5/20/2021	Rm 31	Classroom sink	Initial	<1	6/9/2021	n/a
NY #10478	70174130012	5/20/2021	Rm 32	Classroom sink	Initial	<1	6/9/2021	n/a
NY #10478	70174130013	5/20/2021	Rm 33	Classroom sink	Initial	<1	6/9/2021	n/a
NY #10478	70174130014	5/20/2021	Rm 34	Classroom sink	Initial	<1	6/9/2021	n/a
NY #10478	70174130015	5/20/2021	2nd/3rd Hallway	Drinking fountain	Initial	<1	6/9/2021	n/a

NY #10478	70174130016	5/20/2021	Rm 35	Drinking fountain	Initial	7.8	6/9/2021	n/a
NY #10478	70174130017	5/20/2021	Rm 35	Classroom sink	Initial	4.6	6/9/2021	n/a
NY #10478	70174130018	5/20/2021	Rm 36	Drinking fountain	Initial	2.2	6/9/2021	n/a
NY #10478	70174130019	5/20/2021	Rm 36	Classroom sink	Initial	7.2	6/9/2021	n/a
NY #10478	70174130020	5/20/2021	Rm 37	Drinking fountain	Initial	4.7	6/9/2021	n/a
NY #10478	70174130021	5/20/2021	Rm 37	Classroom sink	Initial	4.4	6/9/2021	n/a
NY #10478	70174130022	5/20/2021	Rm 38	Drinking fountain	Initial	<1	6/9/2021	n/a
NY #10478	70174130023	5/20/2021	Rm 38	Classroom sink	Initial	5.5	6/9/2021	n/a
NY #10478	70174130024	5/20/2021	Rm 39	Classroom sink	Initial	5.3	6/9/2021	n/a
NY #10478	70174136001	5/20/2021	School Kitchen	Kitchen sink	Initial	13.9	6/9/2021	n/a
NY #10478	70174136002	5/20/2021	Rm 57	Classroom sink	Initial	8	6/9/2021	n/a
NY #10478	70174136003	5/20/2021	Rm 59	Classroom sink	Initial	10.3	6/9/2021	n/a
NY #10478	70174136004	5/20/2021	Rm 59	Drinking fountain	Initial	19.3	6/9/2021	removed from service
NY #10478	70174136005	5/20/2021	Rm 61	Drinking fountain	Initial	13.4	6/9/2021	n/a
NY #10478	70174136006	5/20/2021	Rm 61	Classroom sink	Initial	11.7	6/9/2021	n/a
NY #10478	70174136007	5/20/2021	Rm 63	Art room sink	Initial	11.5	6/9/2021	n/a
NY #10478	70174136008	5/20/2021	Rm 63	Art room sink	Initial	21.9	6/9/2021	handwashing only sign
NY #10478	70174136009	5/20/2021	Rm 63	Art room sink	Initial	12.3	6/9/2021	n/a
NY #10478	70174136010	5/20/2021	Rm 63	Art room sink	Initial	5.5	6/9/2021	n/a
NY #10478	70174136011	5/20/2021	Rm 63	Art room sink	Initial	6	6/9/2021	n/a
NY #10478	70174136012	5/20/2021	Hallway Boys Café Wing	Bathroom sink	Initial	2	6/9/2021	n/a
NY #10478	70174130613	5/20/2021	Hallway Girls Café Wing	Bathroom sink	Initial	7.4	6/9/2021	n/a
NY #10478	70174136014	5/20/2021	Hall Fountain Café Wing	Drinking fountain	Initial	<1	6/9/2021	n/a
NY #10478	70174136015	5/20/2021	Hall Fountain Café Wing	Drinking fountain	Initial	<1	6/9/2021	n/a
NY #10478	70174136016	5/20/2021	Custodial closet	Slop sink	Initial	<1	6/9/2021	n/a
NY #10478	70174130617	5/20/2021	Hall Fountain Wing 1	Drinking fountain	Initial	<1	6/9/2021	n/a
NY #10478	70174136018	5/20/2021	Hallway Girls 5th gr. Wing	Bathroom sink	Initial	2	6/9/2021	n/a
NY #10478	70174136019	5/20/2021	Hallway Girls 5th gr. Wing	Bathroom sink	Initial	5.7	6/9/2021	n/a
NY #10478	70174142001	5/20/2021	Hallway Girls 5th Grade	Bathroom sink	Initial	3.2	6/9/2021	n/a
NY #10478	70174142002	5/20/2021	Hallway Boys 5th Grade	Bathroom sink	Initial	9.1	6/9/2021	n/a
NY #10478	70174142003	5/20/2021	Hallway Boys 5th Grade	Bathroom sink	Initial	147	6/9/2021	removed from service
NY #10478	70174142004	5/20/2021	Custodial closet 5th Grade	Slop sink	Initial	15.9	6/9/2021	non-drinking signage
NY #10478	70174142005	5/20/2021	Hall Fountain 5th Grade	Drinking Fountain	Initial	<1	6/9/2021	n/a
NY #10478	70174142006	5/20/2021	Exterior 5th Grade	Exterior spigot	Initial	2.1	6/9/2021	n/a
NY #10478	70174142007	5/20/2021	Teacher's Lounge	Kitchen sink	Initial	14.5	6/9/2021	n/a
NY #10478	70174142008	5/20/2021	Kitchen	Kitchen sink	Initial	2.3	6/9/2021	n/a
NY #10478	70174142009	5/20/2021	Kitchen	Kitchen sink	Initial	1.5	6/9/2021	n/a
NY #10478	70174142010	5/20/2021	Kitchen	Kitchen sink	Initial	1	6/9/2021	n/a
NY #10478	70174142011	5/20/2021	Kitchen	Kitchen sink	Initial	3.1	6/9/2021	n/a
NY #10478	70174142012	5/20/2021	Kitchen	Kitchen sink	Initial	6.8	6/9/2021	n/a
NY #10478	70174142013	5/20/2021	Rm 39	Drinking fountain	Initial	3.9	6/9/2021	n/a
NY #10478	70174142014	5/20/2021	Rm 40	Classroom sink	Initial	8.7	6/9/2021	n/a

NY #10478	70174142015	5/20/2021	Rm 40	Drinking fountain	Initial	2.1	6/9/2021	n/a
NY #10478	70174142016	5/20/2021	Rm 41	Drinking fountain	Initial	2.4	6/9/2021	n/a
NY #10478	70174142017	5/20/2021	Rm 41	Classroom sink	Initial	4.4	6/9/2021	n/a
NY #10478	70174142018	5/20/2021	Rm 42	Drinking fountain	Initial	8	6/9/2021	n/a
NY #10478	70174142019	5/20/2021	Rm 42	Classroom sink	Initial	2.4	6/9/2021	n/a
NY #10478	70174142020	5/20/2021	Hallway Boys 4th Grade	Bathroom sink	Initial	3.8	6/9/2021	n/a
NY #10478	70174142021	5/20/2021	Hallway Boys 4th Grade	Bathroom sink	Initial	40.5	6/9/2021	handwashing only sign
NY #10478	70174142022	5/20/2021	Hallway Girls 4th Grade	Bathroom sink	Initial	10.4	6/9/2021	n/a
NY #10478	70174142023	5/20/2021	Hallway Girls 4th Grade	Bathroom sink	Initial	104	6/9/2021	handwashing only sign
NY #10478	70174142024	5/20/2021	Hallway Girls 5th Grade	Bathroom sink	Initial	2.8	6/9/2021	n/a
NY #10478	70174089021	5/20/2021	Elem Boys Locker Room 2	Bathroom sink	Initial	5.5	6/9/2021	n/a
NY #10478	70174089022	5/20/2021	Elem Boys Locker Room 3	Bathroom sink	Initial	1.2	6/9/2021	n/a
NY #10478	70174089023	5/20/2021	Elem Boys Locker Room 4	Bathroom sink	Initial	17.2	6/9/2021	handwashing only sign
NY #10478	70174089024	5/20/2021	Boys PE Office	Bathroom sink	Initial	8.2	6/9/2021	n/a
NY #10478	70174089025	5/20/2021	Elem Girls Locker Room 1	Bathroom sink	Initial	25.2	6/9/2021	handwashing only sign
NY #10478	70174089026	5/20/2021	Elem Girls Locker Room 2	Bathroom sink	Initial	17.8	6/9/2021	handwashing only sign
NY #10478	70174089027	5/20/2021	Elem Girls Locker Room 3	Bathroom sink	Initial	6.8	6/9/2021	n/a
NY #10478	70174089028	5/20/2021	Girls PE Office	Bathroom sink	Initial	65.7	6/9/2021	handwashing only sign
NY #10478	70174089029	5/20/2021	Nurse's Office	Eyewash Station	Initial	2.3	6/9/2021	n/a
NY #10478	70174089030	5/20/2021	CSE Office	Kitchen sink	Initial	1.6	6/9/2021	n/a
NY #10478	70174089020	5/18/2021	Elem Boys Locker Room	Bathroom sink	Initial	104	6/9/2021	handwashing only sign
NY #10478	70174153004	5/19/2021	Exterior Elem Faucet 1	Outdoor spigot	Initial	91.8	6/9/2021	removed from service
NY #10478	70174153005	5/19/2021	Exterior Elem Faucet 2	Outdoor spigot	Initial	48.6	6/9/2021	removed from service
NY #10478	70174153006	5/19/2021	Exterior Elem Faucet 3	Outdoor spigot	Initial	120	6/9/2021	removed from service