

School Name: Honeoye Secondary School

Lab EPA id#: NY 10478

Method of Analysis: EPA Method 200.8

LabID#	School Sample ID#	Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result mcg/L (ppb)	Lab Report Receipt Date	Action Taken for Outlets Greater than 15 mcg/L
NY #10478	70174090001	5/18/2021	Staff Bath 1st Floor Ms	Bathroom sink	Initial	1.7	6/9/2021	n/a
NY #10478	70174090002	5/18/2021	1st Floor MS Girls	Bathroom sink	Initial	2.2	6/9/2021	n/a
NY #10478	70174090003	5/18/2021	1st Floor MS Boys	Bathroom sink	Initial	2.3	6/9/2021	n/a
NY #10478	70174090004	5/18/2021	2nd Floor MS Girls	Bathroom sink	Initial	1.3	6/9/2021	n/a
NY #10478	70174090005	5/18/2021	2nd Floor MS Boys	Bathroom sink	Initial	1.8	6/9/2021	n/a
NY #10478	70174090006	5/18/2021	Rm 152	Classroom sink	Initial	4	6/9/2021	n/a
NY #10478	70174090007	5/18/2021	Rm 151 #1	Classroom sink	Initial	15.8	6/9/2021	handwashing only sign
NY #10478	70174090008	5/18/2021	Rm 151 #2	Classroom sink	Initial	3.9	6/9/2021	n/a
NY #10478	70174090009	5/18/2021	Rm 151 #4	Classroom sink	Initial	4.3	6/9/2021	n/a
NY #10478	70174090010	5/18/2021	Hall Boys #1	Bathroom sink	Initial	19.1	6/9/2021	handwashing only sign
NY #10478	70174089001	5/18/2021	Rm 153 #1	Classroom sink	Initial	3.8	6/9/2021	n/a
NY #10478	70174089002	5/18/2021	Rm 153 #2	Classroom sink	Initial	5.4	6/9/2021	n/a
NY #10478	70174089003	5/18/2021	Rm 153 #3	Classroom sink	Initial	<1	6/9/2021	n/a
NY #10478	70174089004	5/18/2021	Rm 152 #1	Classroom sink	Initial	6.1	6/9/2021	n/a
NY #10478	70174089005	5/18/2021	Rm 152 #2	Classroom sink	Initial	2.3	6/9/2021	n/a
NY #10478	70174090006	5/18/2021	Staff Bath 2nd Floor MS	Bathroom sink	Initial	1.5	6/9/2021	n/a
NY #10478	70174090007	5/18/2021	HTA Office 2nd Floor MS	Office sink	Initial	14.9	6/9/2021	n/a
NY #10478	70174090008	5/18/2021	Custodial sink MS 1st Floor	Slop sink	Initial	44.2	6/9/2021	non-drinking signage
NY #10478	70174090009	5/18/2021	Custodial sink MS 2nd Floor	Slop sink	Initial	2.4	6/9/2021	n/a
NY #10478	70174090010	5/18/2021	Hall MS 1st Floor	Drinking Fountain	Initial	1.1	6/9/2021	n/a
NY #10478	70174090011	5/18/2021	Hall MS 2nd Floor	Drinking Fountain	Initial	1.2	6/9/2021	n/a
NY #10478	70174090012	5/18/2021	District Office	Office sink	Initial	1.8	6/9/2021	n/a
NY #10478	70174090013	5/18/2021	MS Office	Office sink	Initial	89.7	6/9/2021	handwashing only sign
NY #10478	70174090014	5/18/2021	Cross Hall Girls #1	Bathroom sink	Initial	22.3	6/9/2021	handwashing only sign
NY #10478	70174090015	5/18/2021	Cross Hall Girls #2	Bathroom sink	Initial	8.1	6/9/2021	n/a
NY #10478	70174133003	5/20/2021	Hallway Foreign Lang	Drinking Fountain	Initial	2.4	6/9/2021	n/a
NY #10478	70174133004	5/20/2021	Rm 151 Sink 3	Classroom sink	Initial	9.3	6/9/2021	n/a
NY #10478	70174949012	5/21/2021	Exterior MS District	Outdoor spigot	Initial	16.8	6/9/2021	Removed from service
NY #10478	70174090016	5/18/2021	Boys Cross Hall	Bathroom sink	Initial	25	6/9/2021	handwashing only sign
NY #10478	70174090017	5/18/2021	Ice Machine Cross Hall	Ice Machine	Initial	<1	6/9/2021	n/a
NY #10478	70174090018	5/18/2021	HS Boys Locker Room	Bathroom sink	Initial	7.6	6/9/2021	n/a
NY #10478	70174090019	5/18/2021	Boys Locker Room	Slop sink	Initial	81.7	6/9/2021	non-drinking signage
NY #10478	70174090020	5/18/2021	HS Boys PE Office	Bathroom sink	Initial	74.9	6/9/2021	handwashing only sign

NY #10478	70174090021	5/18/2021	HS Girls Locker Room	Slop sink	Initial	11.5	6/9/2021	n/a
NY #10478	70174090022	5/18/2021	HS Girls PE Office	Bathroom sink	Initial	101	6/9/2021	handwashing only sign
NY #10478	70174090023	5/18/2021	HS Girls Locker Room	Bathroom sink	Initial	29.7	6/9/2021	handwashing only sign
NY #10478	70174090024	5/18/2021	Foyer Auditorium	Drinking Fountain	Initial	<1	6/9/2021	n/a
NY #10478	70174090025	5/18/2021	Foyer Auditorium Girls	Bathroom sink	Initial	2	6/9/2021	n/a
NY #10478	70174090026	5/18/2021	Foyer Auditorium Boys	Bathroom sink	Initial	5.2	6/9/2021	n/a
NY #10478	70174090027	5/18/2021	Concession Stand Sink	Kitchen sink	Initial	1.8	6/9/2021	n/a
NY #10478	70174090028	5/18/2021	Athletic Director 1st Floor	Office sink	Initial	<1	6/9/2021	n/a
NY #10478	70174090029	5/18/2021	Band Room	Classroom sink	Initial	1.4	6/9/2021	n/a
NY #10478	70174090030	5/18/2021	Girls HS 2nd Floor #1	Bathroom sink	Initial	25	6/9/2021	handwashing only sign
NY #10478	70174090031	5/18/2021	Girls HS 2nd Floor #2	Bathroom sink	Initial	20.4	6/9/2021	handwashing only sign
NY #10478	70174090032	5/18/2021	Girls HS 2nd Floor #3	Bathroom sink	Initial	14.4	6/9/2021	handwashing only sign
NY #10478	70174090033	5/18/2021	Boys HS 2nd Floor #1	Bathroom sink	Initial	91.8	6/9/2021	handwashing only sign
NY #10478	70174090034	5/18/2021	Boys HS 2nd Floor #2	Bathroom sink	Initial	244	6/9/2021	handwashing only sign
NY #10478	70174090035	5/18/2021	Boys HS 2nd Floor #3	Bathroom sink	Initial	93.8	6/9/2021	handwashing only sign
NY #10478	70174090036	5/18/2021	Custodial HS 2nd Floor	Slop sink	Initial	20.9	6/9/2021	non-drinking signage
NY #10478	70174090037	5/18/2021	Hall Fountain HS 2nd Floor	Drinking Fountain	Initial	2.6	6/9/2021	n/a
NY #10478	70174089011	5/18/2021	Boys Foreign Language #1	Bathroom sink	Initial	124	6/9/2021	handwashing only sign
NY #10478	70174089012	5/18/2021	Boys Foreign Language #2	Bathroom sink	Initial	30.2	6/9/2021	handwashing only sign
NY #10478	70174089013	5/18/2021	Girls Foreign Language #1	Bathroom sink	Initial	55.7	6/9/2021	handwashing only sign
NY #10478	70174089014	5/18/2021	Girls Foreign Language #2	Bathroom sink	Initial	6.8	6/9/2021	n/a
NY #10478	70174089015	5/18/2021	Girls Foreign Language #3	Bathroom sink	Initial	24.9	6/9/2021	handwashing only sign
NY #10478	70174089016	5/18/2021	Rm 149 #1	Art room sink	Initial	7.8	6/9/2021	n/a
NY #10478	70174089017	5/18/2021	Rm 149 #2	Art room sink	Initial	7.3	6/9/2021	n/a
NY #10478	70174089018	5/18/2021	Rm 149 #3	Art room sink	Initial	6.8	6/9/2021	n/a
NY #10478	70174089019	5/18/2021	Rm 140 Secondary Library	Office sink	Initial	15.2	6/9/2021	handwashing only sign
NY #10478	70174089031	5/18/2021	CORAL Laundry Rm 103	Utility sink	Initial	152	6/9/2021	non-drinking signage
NY #10478	70174089032	5/18/2021	CORAL Classroom #1	Kitchen sink	Initial	2.4	6/9/2021	n/a
NY #10478	70174089033	5/18/2021	CORAL Classroom #2	Kitchen sink	Initial	<1	6/9/2021	n/a
NY #10478	70174089034	5/18/2021	Maintenance Break Room	Breakroom sink	Initial	3.9	6/9/2021	n/a
NY #10478	70174089035	5/18/2021	Maintenance Laundry	Work sink	Initial	2.4	6/9/2021	n/a
NY #10478	70174153001	5/19/2021	Exterior Faucet HS #1	Outdoor spigot	Initial	2.7	6/9/2021	n/a
NY #10478	70174153002	5/19/2021	Exterior Faucet HS #2	Outdoor spigot	Initial	6.6	6/9/2021	n/a
NY #10478	70174153003	5/19/2021	Exterior Faucet HS #3	Outdoor spigot	Initial	9	6/9/2021	n/a
NY #10478	70174153007	5/19/2021	Grounds Building/Barn	Bathroom sink	Initial	27.1	6/9/2021	handwashing only sign
NY #10478	70174153008	5/19/2021	Grounds Building/Barn	Slop sink	Initial	3.6	6/9/2021	n/a
NY #10478	70174153009	5/19/2021	Exterior Athletic Field #1	Drinking Fountain	Initial	<1	6/9/2021	n/a
NY #10478	70174153010	5/19/2021	Exterior Athletic Field #2	Drinking Fountain	Initial	14.4	6/9/2021	n/a

NY #10478	70174153011	5/19/2021	Exterior Athletic Field #3	Drinking Fountain	Initial	10.1	6/9/2021	n/a
-----------	-------------	-----------	----------------------------	-------------------	---------	------	----------	-----